





Main Power				
Voltage (VAC)	Phase	Power (kW)*	Resolution (kW)	Line Current-Amps
480	3	1000.0	5.0	1203
240	3	1000.0	5	2605
208	3	793.1	0.94	2895
*kW output tolerance is +/- 5%				
Blower/Control Power			FLA	
Voltage	Phase	Frequency	HP/Power	FLA
480V	3	60Hz	10	34
240V	3	60Hz	10	38
208V	3	60Hz	10	32



Control Detail



Sheet 1 Of 13

Tolerances	
.XX = +/- .03"	
.XXX = +/- .005"	
Ang = +/- .2°	

Rev.	Description	Rev. By	Date
1	ECN-4778 - Added pressure switch tubing on "+" side	TLS	5/26/2020

MOSEBACH MANUFACTURING COMPANY
 1477 McLoughlin Run Road
 Pilsbury, Pa. 15241
 Phone: 412-230-0200 Fax: 412-230-0235 Web: www.mosebach.com



1000kW @ 480/240VAC
Load Bank

Drawn	Model	Approved	Part Number	Rev.
TLS	TLS	GMT	XL1000G3-	1