

UNITS HAVING "W" DIMENSION OF 60" OR LESS.

- 4. POWER DISTRIBUTION BLOCK OR BUSS BAR PROVIDED ON SUPPORT BRACKET DEPENDING ON LOAD BANK VOLTAGE AND KW.
- 3. WHEN UNIT IS OVER 60" WIDE, MOUNT VIA TOP & BOTTOM FLANGES. FABRICATE A STRUCTURE AT OUTBOUND BOTTOM FLANGE IF REQUIRED FOR ADDED SUPPORT.
- 2. ALL DIMENSIONS ARE APPROX.
- 1. WEIGHT:

NOTES:



RADIATOR MOUNT LOAD BANK GENERAL REFERENCE OUTLINE DRAWING

Model 1100 - 26"

Rev. F