



8. PROPER LOAD BANK INSTALLATION/ORIENTATION REQUIRES ALL THE RESISTOR ELEMENTS TO BE LOCATED DIRECTLY OVER THE AIR DISCHARGE AREA TO PROVIDE THE MOST EFFECTIVE COOLING.
7. AVAILABLE LENGTH & WIDTH OF GENSET OPENING DEPENDS ON LOCATION OF THE ENGINE EXHAUST OUTLET AND/OR OTHER COMPONENTS BLOCKING AIR FLOW.
6. BUS BARS SUPPLIED DEPENDING ON LOAD BANK VOLTAGE AND KW.
5. CONTROL PANEL IS ALWAYS MOUNTED REMOTELY
4. MINIMUM CFM REQUIRED THROUGH LOAD BANK IS _____ CFM, MAINTAIN MINIMUM 850 FT/MIN THROUGH LOAD BANK RESISTOR SECTION.
3. MOUNT LOAD BANK USING FLANGES ONLY.
2. ALL DIMENSIONS ARE APPROX. IN INCHES.
1. WEIGHT: ____ LBS. APPROX.



HORIZONTAL RADIATOR MOUNT LOAD BANK
GENERAL REFERENCE OUTLINE DRAWING

Model 1500

Rev -

